

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (0999)		15 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
	Asbestos (1094)		1 routine (RT) per nine years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/25		
Total Coliform (3100)		15 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
	Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
1-6 KNICKERBOCKER LN (2001)	10/1/18 - 12/31/18	12/1-12/31	Complete
	1/1/19 - 3/31/19	3/1-3/31	Complete
	4/1/19 - 6/30/19	6/1-6/30	
	7/1/19 - 9/30/19	9/1-9/30	
40-53 S. COBBLERS CRT (2003)	10/1/18 - 12/31/18	12/1-12/31	Complete
	1/1/19 - 3/31/19	3/1-3/31	Complete
	4/1/19 - 6/30/19	6/1-6/30	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/19 - 9/30/19	9/1-9/30	
30-39 SOUTH STREET (2004)	10/1/18 - 12/31/18	12/1-12/31	Complete
	1/1/19 - 3/31/19	3/1-3/31	Complete
	4/1/19 - 6/30/19	6/1-6/30	
	7/1/19 - 9/30/19	9/1-9/30	
80-87 QUARRY DOCK RD (2006)	10/1/18 - 12/31/18	12/1-12/31	Complete
	1/1/19 - 3/31/19	3/1-3/31	Complete
	4/1/19 - 6/30/19	6/1-6/30	
	7/1/19 - 9/30/19	9/1-9/30	

Lead And Copper (PBCU)		30 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/20	6/1-9/30	

Physical Parameters (PPS)		15 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **INDUSTRIAL PARK ROAD WTP ENTRY POINT (WSF ID: 00702)**

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-INDUSTRIAL PARK (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-INDUSTRIAL PARK (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Monitoring Requirements

Water System Facility: **INDUSTRIAL PARK ROAD WTP ENTRY POINT (WSF ID: 00702)**

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-INDUSTRIAL PARK (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-INDUSTRIAL PARK (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-INDUSTRIAL PARK (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-INDUSTRIAL PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-INDUSTRIAL PARK (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: **WELL 2 WTP ENTRY POINT (WSF ID: 00703)**

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 2 (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Monitoring Requirements

Water System Facility: WELL 2 WTP ENTRY POINT (WSF ID: 00703)

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-WELL 2 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-WELL 2 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-WELL 2 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		

Water System Facility: BRIDE BROOK ENTRY POINT-WELLS 3, 3A & 3B (WSF ID: 00704)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-BRIDE BROOK (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-BRIDE BROOK (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-BRIDE BROOK (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-BRIDE BROOK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-BRIDE BROOK (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Water System Facility: WELL 4A WTP ENTRY POINT (WSF ID: 00705)

Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Monitoring Requirements

Water System Facility: WELL 4A WTP ENTRY POINT (WSF ID: 00705)

Net Gross Alpha (4000)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-WELL 4A (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
Uranium (4006)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-WELL 4A (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
Combined Radium-226/228 (4010)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-WELL 4A (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
Gross Beta Particle Activity (4100)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-WELL 4A (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-WELL 4A (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
Tritium (4102)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-WELL 4A (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
Strontium-90 (4174)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-WELL 4A (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-WELL 4A (3)	1/1/18 - 12/31/20			
	1/1/21 - 12/31/23			
Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-WELL 4A (3)	1/1/18 - 12/31/18		Complete	
	1/1/19 - 12/31/19			
	1/1/20 - 12/31/20			
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-WELL 4A (3)	1/1/17 - 12/31/19			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served:

Monitoring Requirements

Water System Facility: WELL 4A WTP ENTRY POINT (WSF ID: 00705)

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **2 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 4A (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Water System Facility: WELL 5 WTP ENTRY POINT (WSF ID: 00706)

Net Gross Alpha (4000) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **2 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		

Water System Facility: WELL 6 WTP ENTRY POINT (WSF ID: 00707)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Monitoring Requirements

Water System Facility: WELL 6 WTP ENTRY POINT (WSF ID: 00707)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 6 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 6 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 6 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 6 (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 6 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 6 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 6 (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Water System Facility: WELL 3A (WSF ID: 1417)			
E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3A (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Monitoring Requirements

Water System Facility: **WELL 3A (WSF ID: 1417)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **WELL 4A (WSF ID: 1839)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4A DODGE POND (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **WELL 6 (WSF ID: 1962)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 6 (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **WELL 1A (WSF ID: 49234)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served:

Monitoring Requirements

Water System Facility: **WELL 1A (WSF ID: 49234)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1A (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **WELL 2A (WSF ID: 56403)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2A (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **WELL 3B (WSF ID: 57523)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3B BRIDE BROOKS (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Monitoring Requirements

Water System Facility: **WELL 3B (WSF ID: 57523)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **WELL 5 (WSF ID: 970)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 5 (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **INDUSTRIAL PARK ROAD WTP ENTRY POINT (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
Start Date: 2/1/2012				
		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		11/1/2018 - 11/30/2018	Y	Y
		12/1/2018 - 12/31/2018	Y	Y
		1/1/2019 - 1/31/2019	Y	Y
		2/1/2019 - 2/28/2019	Y	Y
		3/1/2019 - 3/31/2019	Y	Y
		4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily	
Start Date: 1/1/2005				
		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		11/1/2018 - 11/30/2018	Y	Y
		12/1/2018 - 12/31/2018	Y	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served:

Water System Facility: INDUSTRIAL PARK ROAD WTP ENTRY POINT (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 1/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 1/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Water System Facility: WELL 2 WTP ENTRY POINT (WSFID: 00703)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 2/1/2012			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Water System Facility: WELL 2 WTP ENTRY POINT (WSFID: 00703)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 1/1/2005			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2005			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

Water System Facility: BRIDE BROOK ENTRY POINT-WELLS 3, 3A & 3B (WSFID: 00704)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 2/1/2012			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 1/1/2005			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Water System Facility: BRIDE BROOK ENTRY POINT-WELLS 3, 3A & 3B (WSFID: 00704)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2005			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

Water System Facility: WELL 4A WTP ENTRY POINT (WSFID: 00705)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 2/1/2012			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 1/1/2005			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2005			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Water System Facility: WELL 5 WTP ENTRY POINT (WSFID: 00706)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 2/1/2012			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	N
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 1/1/2005			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2005			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

Water System Facility: WELL 6 WTP ENTRY POINT (WSFID: 00707)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 2/1/2012			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served:

Water System Facility: WELL 6 WTP ENTRY POINT (WSFID: 00707)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 1/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2013	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	PN Certification Received
Chlorine M&R Violation	9/1/18 - 9/30/18	3	12/3/2019		12/13/2019	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	009	BAYREUTHERS BOAT	A	Y		Y	
		010	GUY'S OIL	A	Y			
		011	BLACK POINT REALTY	A	Y			
		012	NIANTIC CENTER SCH	A	Y			
		013	12 ROXBURY RD (PWD)	A	Y			
		014	FIREHOUSE (B PT RD)	A	Y			
		015	108 PENN AVE	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		016	VILLAGE DR	A	Y			
		017	JEAN DR	A	Y			
		018	DEERFIELD KING ARTH	A	Y			
		1001	8 NELSON DR	A		1		
		1002	21 HUNTLEY CT	A		1		
		1003	30 PATTAGANSETT DR	A	Y	1		
		1004	5 WEST RD	A		1		
		1005	2 GREEN TREE DR	A		1		
		1006	36 ROMAGNA RD	A		1		
		1007	6 RAMBLE AVE	A		1		
		1008	4 MONTICELLO DE	A		1		
		1009	7 VILLAGE DR	A		1		
		1101	15 PINE ST	A		1		
		1102	18 HUNTLEY CT	A		1		
		1103	18 SUNNIESIDE DR	A		1		
		1104	3 MAYFIELD TERR	A		1		
		1105	88 SMITH AVE	A		1		
		1106	11 LAKEVIEW AVE	A		1		
		1107	16 DAMON HGTS	A		1		
		1108	14 CAVASIN DR	A		1		
		1109	61 OAKWOOD RD	A		1		
		1110	15 SLEEPY HOLLOW	A		1		
		1111	71 SO WASHINGTON	A		1		
		1112	5 SO LEE	A		1		
		1113	8 JOANNE ST	A		1		
		1114	13 PARK PL	A		1		
		1115	24 SMITH AVE	A		1		
		1116	88 GIANTS NECK	A		1		
		1117	15 SURRY LA	A		1		
		1118	12 CAVSIN DR	A		1		
		1119	15 MERRYWOOD DR	A		1		
		1120	17 ROMAGNA RD	A		1		
		1121	10 CYPRESS WAY	A		1		
		1122	17 FILOSI RD	A		1		
		1123	3 BRAINARD RD	A		1		
		1124	41 RIVERVIEW RD	A		1		
		1125	42 SMITH AVE	A		1		
		1126	9 BLACK POINT RD	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		1127	110 BAYVIEW RD	A		1		
		1128	10 OLD OAK LA	A		1		
		1129	1 SO PINE ST	A		1		
		1130	69 SMITH ST	A		1		
		1131	34 BROADWAY	A		1		
		1132	7 SAUNDERS DR	A		1		
		1133	184 WEST MAIN ST	A		1		
		1134	14 VILLAGE DR	A		1		
		1135	12 NELSON DR	A		1		
		1136	20 VILLAGE DR	A		1		
		1137	30 VILLAGE DR	A		1		
		1138	32 VILLAGE DR	A		1		
		1139	34 VILLAGE DR	A		1		
		1140	36 VILLAGE DR	A		1		
		1141	38 VILLAGE DR	A		1		
		1142	40 VILLAGE DR	A		1		
		1143	47 MAYFIELD TERRACE	A		1		
		1144	45 MAYFIELD TERRACE	A		1		
		1145	41 MAYFIELD TERRACE	A		1		
		1146	36 MAYFIELD TERRACE	A		1		
		1147	44 MAYFIELD TERRACE	A		1		
		1148	20 MAYFIELD TERRACE	A		1		
		1149	19 MAYFIELD TERRACE	A		1		
		1150	16 SLEEPY HOLLOW ROA	A		1		
		1151	40 SLEEPY HOLLOW ROA	A		1		
		1152	47 SLEEPY HOLLOW ROA	A		1		
		1153	117 SLEEPY HOLLOW RO	A		1		
		1154	115 SLEEPY HOLLOW RO	A		1		
		1155	21 FILOSI ROAD	A		1		
		1156	57 SPRING ROCK RD	A		1		
		1157	55 SPRING ROCK RD	A		1		
		1158	53 SPRING ROCK RD	A		1		
		1159	49 SPRING ROCK RD	A		1		
		1160	47 SPRING ROCK RD	A		1		
		1161	7 SPRING ROCK RD	A		1		
		1162	5 SPRING ROCK RD	A		1		
		1163	3 SPRING ROCK RD	A		1		
		1164	12 SPRING ROCK RD	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		1165	14 SPRING ROCK RD	A		1		
		1166	15 SPRING ROCK RD	A		1		
		1167	44 SPRING ROCK RD	A		1		
		1168	7 JEAN DRIVE	A		1		
		1169	15 JEAN DRIVE	A		1		
		1170	4 JEAN DRIVE	A		1		
		1171	22 MACKINNON PL	A		1		
		1172	26 MACKINNON PL	A		1		
		1173	8 JEAN DRIVE	A		1		
		1174	8 MORRIS LN	A		1		
		1175	11 MORRIS LN	A		1		
		1176	25 MACKINNON PL	A		1		
		1177	8 SEEBECK RD	A		1		
		1178	9 SEEBECK RD	A		1		
		1179	5 SEEBECK RD	A		1		
		1180	15 MORRIS LN	A		1		
		1181	9 MORRIS LN	A		1		
		1182	8 MACKINNON PL	A		1		
		1183	12 MACKINNON PL	A		1		
		1184	20 MACKINNON PL	A		1		
		1185	24 MACKINNON PL	A		1		
		1186	11 SEEBECK RD	A		1		
		1187	7 SEEBECK RD	A		1		
		1188	2 MORRIS LN	A		1		
		1189	7 MORRIS LN	A		1		
		1190	16 MACKINNON PL	A		1		
		1191	28 MACKINNON PL	A		1		
		1192	13 MACKINNON PL	A		1		
		1193	5 MACKINNON PL	A		1		
		1194	63 SLEEP HOLLOW RD	A		1		
		1195	18 WILDWOOD DR	A		1		
		1196	13 JEAN DRIVE	A		1		
		2001	1-6 KNICKERBOCKER LN	A				Y
		2002	1-6 RED FOX ROAD	A				
		2003	40-53 S. COBBLERS CR	A				Y
		2004	30-39 SOUTH STREET	A				Y
		2005	14-24 LEGENDARY ROAD	A				
		2006	80-87 QUARRY DOCK RD	A				Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		4	GENERIC DISTRIBUTION	A	Y			
		901	BLACK PT SEWER PS	A			Y	
		902	CAMP RELL	A			Y	
		903	NIANTIC SEWER PS	A			Y	
		904	BUSH HILL HYD	A			Y	
		905	L.B. HAYNES SCHOOL	A			Y	
		906	COREY LA	A			Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00702	INDUSTRIAL PARK ROAD WTP ENTRY POINT	3	EP-INDUSTRIAL PARK	A				
00703	WELL 2 WTP ENTRY POINT	3	EP-WELL 2	A				
00704	BRIDE BROOK ENTRY POINT- WELLS 3, 3A & 3B	3	EP-BRIDE BROOK	A				
00705	WELL 4A WTP ENTRY POINT	3	EP-WELL 4A	A				
00706	WELL 5 WTP ENTRY POINT	3	EP-WELL 5	A				
00707	WELL 6 WTP ENTRY POINT	3	EP-WELL 6	A				
00708	DARROW POND ENTRY POINT							
1417	WELL 3A	2	WELL 3A	A				
1839	WELL 4A	2	WELL 4A DODGE POND	A				
1962	WELL 6	2	WELL 6	A				
49234	WELL 1A	2	WELL 1A	A				
50077	SLEEP HOLLOW ELDERLY HOUSING TANK							
50079	SLEEPY HOLLOW PUMP STATION							
51321	WELL 6 WTP							
52044	ORCHARD WOODS TANK							
52046	ORCHARD WOODS PUMP STATION							
52136	ROXBURY ROAD STORAGE TANK							
52138	BOSTON POST ROAD STORAGE TANK							
52140	DEERFIELD PUMP STATION							
52142	CEDAR BROOK PUMP STATION							
52144	CHAPMAN WOODS PUMP STATION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
52146	CHAPMAN WOOD HYDROPNEUMATIC STORAGE TANK							
52148	VILLAGE DRIVE PUMP STATION							
52152	ANCIENT HIGHWAY PUMP STATION							
52154	ANCIENT HWY HYDROPNEUMATIC STORAGE TANK							
52156	MACKINNON PLACE PUMP STATION							
52160	SUNRISE TRAIL PUMP STATION							
52162	SUNRISE TRL HYDROPNEUMATIC STORAGE TANK							
52164	JEAN DRIVE PUMP STATION							
52166	JEAN DRIVE HYDROPNEUMATIC STORAGE TANK							
56403	WELL 2A	2	WELL 2A	A				
57523	WELL 3B	2	WELL 3B BRIDE BROOKS	A				
58947	INTERCONNECTION - NEW LONDON							
58949	BUTLERTOWN ROAD TANK							
58951	EAST LYME PUMP STATION							
58953	NEW LONDON PUMP STATION							
58970	DEERFIELD HYDROPNEUMATIC STORAGE TANK							
58972	CEDAR BROOK HYDROPNEUMATIC STORAGE TANK							
59628	GATEWAY COMMONS PUMP STATION							
629	WELL 4A WTP							
630	WELL 5 WTP							
65	WELL 1A (INDUSTRIAL PARK ROAD) WTP							
66	WELL 2/2A WTP							
67	BRIDE BROOK - WELLS 3/3A/3B TP							
970	WELL 5	2	WELL 5	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served:

Certified Operator Information

Water System Facility: WELL 5 WTP (WSF ID: 630)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ALFIERI, MARK	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2021
LARSON, ALLEN L.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2020

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
MCGINTY, VINCENT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2020
CUNNINGHAM, ROBERT W.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2020
LARSON, ALLEN L.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2020
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2019

Water System Facility: WELL 1A (INDUSTRIAL PARK ROAD) WTP (WSF ID: 65)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ALFIERI, MARK	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2021
MCGINTY, VINCENT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2020
LARSON, ALLEN L.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2020

Water System Facility: WELL 2/2A WTP (WSF ID: 66)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ALFIERI, MARK	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2021
MCGINTY, VINCENT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2020
LARSON, ALLEN L.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2020

Water System Facility: BRIDE BROOK - WELLS 3/3A/3B TP (WSF ID: 67)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ALFIERI, MARK	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2021
MCGINTY, VINCENT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2020

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				6,119				

Towns Served:

Certified Operator Information

Water System Facility: BRIDE BROOK - WELLS 3/3A/3B TP (WSF ID: 67)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LARSON, ALLEN L.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2020

Water System Facility: WELL 4A WTP (WSF ID: 629)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ALFIERI, MARK	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2021
LARSON, ALLEN L.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2020

Water System Facility: WELL 6 WTP (WSF ID: 51321)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ALFIERI, MARK	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2021
LARSON, ALLEN L.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2020
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2019

Contact Information

Name				Organization		Job Title		
Mr. Bradford C. Kargl				Town of East Lyme		Municipal Util. Engr		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
108 Pennsylvania Avenue			P.O. Box 519			Niantic	CT	06357
Business Phone		Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-739-6931		1139	860-739-6930		860-739-4434	bkargl@eltownhall.com		

Contact Role(s): Administrative Contact

Name				Organization		Job Title		
Mr. Mark Nickerson				Town of East Lyme		First Selectman		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P.O. Box 519						Niantic	CT	06357
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address	
860-691-4110							mnickerson@eltownhall.com	

Contact Role(s): Legal Contact

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0450011	EAST LYME WATER & SEWER COMMISSION			C	15,245	L	SWP
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served:

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.